

Subject: Addendum #2

Client: AC+Co Architects

Notes: Addendum #2

Project: WVHA Pioneer Village Tenant Unit Meters

Project.: 3032405

Location Salem, Oregon

Date: 2024-04-29

**DRAWINGS – Revise per attached drawing unless otherwise noted.**

**E0.2 (Replace Sheet)**

1. Revised one-line diagram to meter feeders at existing unit busway located in the mechanical core of each 4-plex.
2. Removed wireless repeaters.
3. Revised sheet keynotes 1-3.

**E1.1 (Replace Sheet)**

1. Removed wireless repeater from laundry building.

**E2.1 (Replace Sheet)**

1. Removed demolition unit plan.
2. Removed demolition and removal of existing meters.
3. Added meter enclosure and 0.75" conduit from enclosure to unit busway for meter wiring.
4. Revised general & sheet keynotes.

**SPECIFICATIONS – Replace per attached sections noted below (Note – additions are in bold, deletions have a strikethrough).**

**SECTION 26 05 33 – RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS.**

**SECTION 26 09 13 – ELECTRICAL POWER MONITORING.**

END OF NARRATIVE